



OPEN MEETING AGENDA ITEM

Los Cerros Water

4003 N. Flowing Wells Road, Suite 111 • Tucson, Arizona 85705-2499
(520) 293-5500 • Fax: (520) 293-3810
loscerroswater@comcast.net • www.loscerroswater.com



0000169150

ORIGINAL

2016 MAR 21 A 11:58


AZ CORP COMMISSION
DOCKET CONTROL

March 17, 2016

Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Arizona Corporation Commission
DOCKETED

MAR 21 2016



Docket No. W-02747A-15-0293

Re: Notice of Compliance 2016

Please find attached the Original and 13 copies of our most current Pima County Department of Environmental Quality Notice of Compliance for Los Cerros Water Company, Inc.

Please attach this additional updated document to Docket No. W-02747A-15-0293.

Thank you.

Jody Carlson, Secretary

Email: loscerroswater@comcast.net

Docket Control #
W-02747A-15-0293



PIMA COUNTY
ENVIRONMENTAL QUALITY

33 N. Stone Avenue, Suite 700
Tucson, Arizona 85701-1429
www.pima.gov/deq

Ursula Nelson, P.E.
Director

(520) 724-7400
FAX (520) 838-7432

March 16, 2016

Los Cerros Water Co.
Attn: Jody Carlson
4003 N. Flowing Wells Rd.
Tucson, Arizona 85705-2404

Re: Letter of Compliance for Los Cerros Water Co., Public Water System (10-128)

Dear Water System Owner/Operator:

Enclosed is a copy of an Inspection Summary report prepared by our staff concerning the referenced facility. The inspection was performed on March 16, 2016 in accordance with Arizona Revised Statutes (A.R.S.) §49-351 et.seq. and Arizona Administrative Code (A.A.C.) R18-4-208.

No violations were observed in the operation or maintenance of this system and any previous violations have been corrected. This report addresses the system's compliance with respect to monitoring, reporting, public notice, certified operator and physical facility requirements. For information regarding those areas, please contact Pima County Department of Environmental Quality at 520-724-7400 or the Arizona Department of Environmental Quality at 602-771-4641.

Sincerely,

A handwritten signature in cursive script, reading "Rae Gomez".

Sr. Civil Engineering Assistant

cc: Pima County DEQ (file)
ADEQ - Phoenix

**PIMA COUNTY DEPARTMENT OF ENVIRONMENTAL QUALITY
Water Program**

33 North Stone Ave., Suite 700, Tucson, AZ 85701

NOTICE OF COMPLIANCE - WATER

Facility: Los Cerros Water Co.

System No.: 10-128

Inspected By: Rene Gomez

Inspection Date: 3/16/16

Accompanied By: Steve Carlson

County: Pima

Number of EPDS's/Wells: 5 / 5

System Grade: WD2

Population: 2535

Service Connections: 859

Certified Operator / Operator ID# / Operator Grade: Steve Carlson, 031456, WD2

The water system is in compliance with the following ADEQ requirements:

	YES	NO	N/A
1. Monitoring.....	[X]	[]	[]
2. Reporting.....	[X]	[]	[]
3. Public Notice.....	[X]	[]	[]
4. Certified Operator.....	[X]	[]	[]
5. Physical Facilities.....	[X]	[]	[]

SUMMARY

As a result of the sanitary survey, your water system was found to have no deficiencies in Monitoring, Reporting, Public Notice, Certified Operator and Physical Facilities according to the requirements of the Arizona Department of Environmental Quality rules and regulations.

System Description

This is a community water system consisting of 5 wells, 2 storage tanks, 1 surge tank, 4 pressure tanks, 8 booster pumps and a distribution system.